

# Certificate of Conformity

This is to Certify **DriStud RU 22 & DriStud RU 24**

## Product Description

DriStud RU 22 and DriStud RU 24 are black faced synthetic tri-laminate roofing underlays that are water resistant and vapour permeable.

DiStud RU 22 is lighter grammage self-support roof underlay, whereas DriStud RU 24 is a heavier grammage self-support roof underlay.

## Complies with the Building Code of New Zealand:

If designed, installed and maintained in accordance with the conditions of this certificate, DriStud RU 22 & DriStud RU 24 roofing underlay will comply with;

B1 Structure - B1.3.1, B1.3.2, B1.3.3 (a), (h)

B2 Durability - B2.3.1 (a), B2.3.2 (b)

F2 Hazardous Building Material - F2.3.1

If designed, installed and maintained in accordance with the conditions of this certificate, DriStud RU 22 & DriStud RU 24 roofing underlay will contribute to compliance with;

E2 – External Moisture - E2.3.1, E2.3.2, E2.3.7 (a), (b), (c)

## Subject to the following conditions and limitations:

1. Must be installed in accordance with the DriStud RU 22 Installation Guide Rev 3 (November 2017) and DriStud RU 24 Installation Guide Rev 2.2 (August 2017). This is available at [www.dristud.co.nz](http://www.dristud.co.nz)
2. DriStud RU 22 & DriStud RU 24 may be installed over both timber and steel roof framing.
3. This certificate covers the use of DriStud RU 22 & DriStud RU 24 under: Masonry Tiles, Terracotta tiles, Metal tiles, Profiles metal claddings, slate and composite panels.
4. DriStud RU 22 & DriStud RU 24 can span up to 1200mm between adjacent supports. Where the span exceeds 1200mm or the roof pitch is  $\leq 10^\circ$  a corrosion resistant mesh or alternative i.e. plastic strapping must be used.
5. TCL Hunt Ltd will notifyASUREQuality Ltd in accordance with Regulation 15 of the Building (Product Certification) Regulations 2008.



**CODEMARK™**

## Product Use and Scope

DriStud RU 22 & DriStud RU 24 are roofing underlays intended for use on all new and existing buildings in wind zones up to and including 'Extra High', as defined in NZS 3604:2011.

DriStud RU 22 & DriStud RU 24 can be used where both heavy weight and/or self-support roof underlay is specified.

## Certificate Holder

TCL Hunt Ltd  
7 Fisher Cres, Mt Wellington,  
Auckland 1064  
PO Box 132-166, Sylvia Park,  
Auckland, 1644  
[www.dristud.co.nz](http://www.dristud.co.nz)  
Ph +64 9 526 2700



**JAS-ANZ**



[www.jas-anz.org/register](http://www.jas-anz.org/register)

**CodeMark Certification Body**

ASUREQuality, 11 Hull Road,  
Mt Maunganui  
New Zealand  
Tel. 0508 00 11 22  
[www.asurequality.com](http://www.asurequality.com)

  
John McKay, Chief Executive Officer, ASUREQuality Limited

**Date of Issue**

**10<sup>th</sup> September 2015**

**Certificate Number**

**AQ-090915-CMNZ  
(Rev 5 – Dec 17)**